



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

PHYSICAL AND CHEMICAL TEST REPORTS :

Date Of Collection	19.02.2026
Date Of Analysis	19.02.2026
Date Of Reporting	20.02.2026

SL. NO.	Parameters	Acceptable Limit	Cause of Rejection	RESULT	
				Place	Tarijote, Atharakhai
		(as per IS 10500 : 2012)		Source	Water Purifier
				Sender	Victoria Public School
1.	Turbidity (NTU)	1	5		1.04
2.	pH	6.5 to 8.5	No Relaxation		7.23
3.	TDS(ppm)	500	2000		76
4.	Iron (mg/l)	1.0	No Relaxation		0.08
5.	Res. Chlorine (mg/l)	0.2	1.0		0
6.	Fluoride (mg/l)	1.0	1.5		0.20
7.	Total Hardness(mg/l)	200	600		56

*The tests done with the Sample as deposited by the Party.

Physical & Chemical Test Charge Rs. 900.00/-

Received Vide GRN No. 192025260472906595 Dated: 12/02/2026

Chemist/Bacteriologist,
Darjeeling District Laboratory,
Fulbari, W.T.P.

Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No. 531/SMSD /SD: Dated, Siliguri, the 26.02.2026

Copy forwarded for information and necessary action to:-

1. Victoria Public School .
2. Office Copy.

Report No: Chem/2026/Feb-16

Assistant Engineer-II,
Siliguri Water Supply Division,
P.H. Engineering Dte.



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

BACTERIOLOGICAL ANALYSIS:


Date Of Collection	19.02.2026
Time Of Collection	11.30 AM
Date Of Analysis	19.02.2026 TO 20.02.2026
Date Of Reporting	20.02.2026


Sl No.	Bacteriological Parameters	Acceptable Limit	RESULT	
			Place	Tarijote, Atharakhai
			Source	Water Purifier
			Sender	Victoria Public School
1.	Total Coliform Present/Absent (CFU/100 ML)	Absent		ABSENT
2.	Faecal Coliform Present/Absent (CFU/100 ML)	Absent		ABSENT
3.	WATER BACTERIOLOGICALLY SAFE/UNSAFE	--		SAFE

*The tests done with the Sample as deposited by the Party.

Bacteriological Test Charge Rs. 500.00/-

Received Vide GRN No. 192025260472906595 Dated: 12/02/2026


Chemist/Bacteriologist,
Darjeeling District Laboratory,
Fulbari, W.T.P.



Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No. 532/SWSD /SD: Dated, Siliguri, the 26:02:2026

Copy forwarded for information and necessary action to:-

1. Victoria Public School.
2. Office Copy.

Report No: Bact/2026/Feb-13


Assistant Engineer-II,
Siliguri Water Supply Division
P.H. Engineering Dte.